

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO. 3550-1524:101 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: ABH Manufacturing, Inc., 500 Crossen Ave., Elk Grove Village, IL 60007
Contact: Kurt Shah (847) 437-9901 Fax (847) 437-9918

DESIGN: Models 2100, 2200, 2300 and 2400 electromagnetic door holders. Unit is a door holder, electromagnetic type, and direct pull, rated less than 50 lbs of holding force. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12/24 VAC/VDC and 24/120 VAC/VDC, Max. Holding Force: less than 50 lbs.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, load rating, and UL label.

APPROVAL: Listed as door holders to release a door's closing mechanism where permitted per code. Authority having jurisdiction should be consulted prior to installation. For indoor use and vertical mount only.

09-24-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager